

gas production, mining, or farming.

3). Pesticides and herbicides that may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

4). Organic chemical contaminants, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, which can also come from gas stations, urban storm water runoff, agricultural applications and septic systems.

5). Radioactive contaminants that can be naturally-occurring or be the result of oil and gas production and mining activities.

Lake Casitas has no urban or industrial water runoff and very few residents still in the immediate watershed. There is no oil, gas or mining production above the lake, in our watershed.

### Fluoride

Casitas does not add fluoride, but there is some naturally-occurring fluoride in the water. This level was tested at 0.4 mg/L in the lake source during 2018. For more information on fluoride, check the SWRCB Division of Drinking Water's Fluoridation website for more information on fluoridation, oral health, and current issues: [http://www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/Fluoridation.shtml](http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/Fluoridation.shtml)

### Lead and Copper

The latest results from Casitas' lead and copper testing were below the action levels. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Casitas is responsible for providing high quality drinking water, but cannot control the variety of materials used in private plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. Elevated levels of copper can occur when corrosive water causes leaching of copper plumbing. To prevent leaching, Casitas implemented a corrosion-control plan and adds a small amount of phosphate to the water to lower the corrosivity and reduce copper levels.

Additionally, as part of the school lead testing program, CMWD sampled four schools in our service area, and provided them with testing results.

### Chloramine Disinfection

All public drinking water must be disinfected to prevent water-borne diseases. Casitas disinfects the water by adding chlorine and a small amount of ammonia to the water to form chloramines. Chloramine disinfection is approved by the SWRCB Division of Drinking Water and the US Environmental Protection Agency. Many United States and Canadian cities have used chloramines for decades to disinfect water. Chloramines reduce the level of unwanted disinfection by-products in our water. Disinfection by-products are formed

when chlorine mixes with naturally occurring organic material in water. Currently, regulated disinfection by-products include trihalomethanes and haloacetic acids. Chloramines stop the formation of these by-products, and chloraminated water has less of a chlorine taste and odor than chlorinated water. Chloramines do not pose a health hazard to the general population. Chloraminated water is safe for drinking, bathing, cooking and other normal uses. Two specific groups of people, however, do need to take special care with chloraminated water - kidney dialysis patients and tropical fish hobbyists

### Dialysis Patients Have Special Needs

Kidney patients are not harmed from drinking, cooking or bathing in chloraminated water. However, there is a problem that needs to be addressed for individuals who are undergoing dialysis treatment on artificial kidney machines. Chloramines must not be present in the water used in dialysis machines. Chloramines can be removed through a filtration system. We have worked with the SWRCB Division of Drinking Water to ensure that everyone involved with treatment of dialysis patients is alerted to the facts about chloraminated water.

### Chloramines and Your Aquarium or Fishpond

Chloramines are toxic to fish and other animals that use gills to breathe. While chlorine will evaporate rather quickly from standing water, it may take weeks for chloramines to disappear. Thus it is necessary to dechlorinate water used for aquariums and fishponds. We suggest using a filter system or a dechlorinating agent sold at most pet stores for fresh and saltwater aquariums and fishponds. Another option is to install a high-quality granular activated carbon (GAC) filter in your home. The chloramine residual in water used for fish should be kept below 0.1 parts per million. Contact your local pet store or fish shop for additional assistance.

### Chloramines Are Safe for Plants and Swimming Pools

Chloramines will not affect the chlorine balance in your backyard swimming pool. You still need to add chlorine to eliminate algae and bacterial growth. Chloramines have no effect on plants, vegetables or fruit trees. For more information on chloramines call 805-649-2251, ext. 120.

### Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

### Unregulated Contaminant Monitoring

Unregulated contaminant monitoring helps USEPA and the SWRCB Division of Drinking Water to determine where certain contaminants occur and whether the contaminants need to be regulated. Casitas sampled for unregulated contaminants during 2013; see the table for sampling results.



# Annual Drinking Water Quality Report

## Casitas Municipal Water District System ID # CA5610024, 2018 Data

### High Water Quality Standards

Casitas MWD strives to meet all USEPA and State drinking water health standards. To ensure that you receive the highest quality drinking water, we test beyond what state and federal regulations mandate. This report shows the results of our monitoring for the period of January 1 through December 31, 2018 which is the most recent testing period required.

**Este informe contiene informacion muy importante sobre su agua beber. Traduzcalo o hable con alguien que lo entienda bien. Para la informacion llame por favor 805-649-2251.**

Board meetings are open to the public and are held on the second and fourth Wednesdays of each month at 3:00 p.m. at the district main office, 1055 Ventura Avenue, Oak View, CA, 93022. A recorded version of the meeting is available on the website at [www.casitaswater.org](http://www.casitaswater.org). For additional details on the subjects outlined here, and for more information about Casitas Municipal Water District, visit us at our Web site: [www.casitaswater.org](http://www.casitaswater.org), or call 805-649-2251.

### Ensuring Tap Water Is Safe to Drink

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the State Water Resources Control Board (SWRCB) Division of Drinking Water prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration Regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Drinking water, including bottled water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791). Additional information on bottled water is available on California Department of Public Health's website at <https://www.cdph.ca.gov/Programs/CEH/DFDCS/Pages/FDBPrograms/FoodSafetyProgram/Water.aspx>

### Do You Know the Source of Your Water?

The Casitas Municipal Water District is supplied by a blend of ground water and surface water that is treated before it is distributed to the public. The surface water comes from Lake Casitas, located near the junction of Highway 150 and Santa Ana Road. The ground water is drawn from the Mira Monte



**Jordan Switzer, Water Quality Supervisor for CMWD.**

Well, located in Mira Monte. Most of the watershed is federally protected to limit contamination of the lake. For additional protection, we inspect the watershed on a regular basis.

For more information, you may review the 2016 Watershed Sanitary Survey update and the 2002 Mira Monte Well Drinking Water Source Assessment, which are available at our main office in Oak View, CA.

Lake Casitas is considered to be most vulnerable to the following activities not associated with any detected contaminants: boat services (repair and refinishing), petroleum pipelines and recreation. There have been no contaminants detected in the water supply. However, the lake is still vulnerable to activities located near this major source of our drinking water. The

potential sources of contaminants include private sewage disposal systems; livestock and wildlife grazing; limited pesticide and herbicide use; activities in the surrounding recreation area; unauthorized dumping; limited growth of new homes or urban areas; traffic accidents; and spills. During 2018, results from sampling of the CMWD raw treatment plant influent were non-detect for giardia and cryptosporidium.

The 2002 Drinking Water Source Assessment for the Mira Monte Well is also available to the public at our office. This well is considered to be most vulnerable to the use of fertilizers and animal grazing, which raise nitrate levels in the water. In addition, the Mira Monte Well may be vulnerable to activities associated with an urban environment. However, these activities have not resulted in contamination of the well.

### Influences on Your Water Quality

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity.

Contaminants that may be present in source water include:

1). Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

2). Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff; industrial or domestic wastewater discharges, oil and

*Continued on page 4 >*

# Casitas MWD Water Quality Table, 2018 Data, ID CA5610024

TURBIDITY	MCL (MRDL)	PHG, (MCLG) (MRDLG)	LAKE CASITAS TREATED WATER						Year Tested		Source of Contamination
			AVERAGE			RANGE			Lake or Distribution System	Mira Monte Well	
	Treatment technique (TT)										
Filter Effluent Turbidity (NTU) <sup>a</sup>	1 NTU	NA	highest value = 0.07			0.01-0.07			2018	NA	Soil runoff
	95% < 0.2 NTU		100% of turbidity measurements were < 0.2 NTU						2018	NA	
			100% = lowest monthly % of samples meeting turbidity limits								
MICROBIOLOGICAL			AVERAGE			RANGE					
Total Coliform Bacteria <sup>b</sup>	> 1 positive sample/month	(0)	0			0			2018	NA	Naturally present in the environment
E. Coli Bacteria	> 1 positive sample/month	(0)	0			0			2018	NA	Human and animal fecal waste
INORGANIC CHEMICALS			LAKE CASITAS TREATED		MIRA MONTE WELL		DISTRIBUTION SYSTEM				
			AVERAGE	RANGE	AVERAGE	RANGE	AVERAGE	RANGE			
Barium (ppm)	1	2	0.1	NA	0.1	NA	NA	NA	2018	2016	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits
Fluoride (ppm)	2.0	1	0.4	NA	0.6	NA	NA	NA	2018	2016	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate as N (ppm) <sup>c</sup>	10	10	ND	NA	9.3	7.4-10.5	0.8	0.5-1.0	2018	2018	Runoff and leaching from fertilizer use; leaching from tanks and sewerage; erosion from natural products
DISINFECTION BY-PRODUCTS AND DISINFECTANT RESIDUALS			DISTRIBUTION SYSTEM								
			AVERAGE			RANGE					
Chloramines (ppm)	[4.0]	[4.0]	2.5			0.8-3.8			2018	NA	Drinking water disinfectant added for treatment
Trihalomethanes (ppb)	80	NA	62			46-69			2018	NA	By-product of drinking water disinfection
Haloacetic acids (ppb)	60	NA	48			21-61			2018	NA	By-product of drinking water disinfection
INDIVIDUAL TAP MONITORING FOR: LEAD AND COPPER											
	Regulatory Action Level	PHG	# of samples collected	Homes above RAL	Level detected at 90th percentil				Year Tested		
Lead (ppb) <sup>e</sup>	15	0.2	20	0	ND				2017	NA	Internal corrosion of household plumbing systems; discharges from industrial manufacturers; erosion of natural products
Copper (ppm) <sup>e</sup>	1.3	0.3	20	1	1.0				2017	NA	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead School			Number of schools requesting lead sampling = 4					2017	NA	Internal corrosion of end-user plumbing systems; discharges from industrial manufacturers; erosion of natural products	

## Secondary Aesthetic Standards

CONSTITUENTS	State MCL	PHG/NL	LAKE CASITAS TREATED WATER		MIRA MONTE WELL		DISTRIBUTION SYSTEM		Year Tested		Source of Contamination
			AVERAGE	RANGE	AVERAGE	RANGE	AVERAGE	RANGE	Lake	Well <sup>d</sup>	
Turbidity(NTU)	5	NA	0.2	NA	0.2	NA	0.3 <sup>g</sup>	0.1-0.9 <sup>g</sup>	2018	2016	Soil run-off
Total Dissolved Solids (ppm)	1000	NA	390	NA	380	NA	NA	NA	2018	2016	Run-off/leaching from natural deposits
Specific Conductance (uS/cm)	1600	NA	652	NA	633	NA	648 <sup>g</sup>	568-687 <sup>g</sup>	2018	2016	Substances that form ions in water; seawater influence
Chloride (ppm)	500	NA	24	NA	58	NA	NA	NA	2018	2016	Run-off/leaching from natural deposits; seawater influence
Sulfate (ppm)	500	NA	163	NA	37.9	NA	NA	NA	2018	2016	Run-off/leaching from natural deposits; industrial wastes
Zinc (ppm)	5	NA	ND	NA	0.12	0.09-0.15	NA	NA	2018	2016	Run-off /leaching from natural deposits; industrial wastes
ADDITIONAL CONSTITUENTS											
			LAKE CASITAS TREATED WATER		MIRA MONTE WELL		DISTRIBUTION SYSTEM		Year Tested		
			AVERAGE	RANGE	AVERAGE	RANGE	AVERAGE	RANGE	Lake	Well <sup>d</sup>	
UCMR 3 Monitoring	NL										
Chlorate (ppb)	800	NA	ND	ND	176	65-290	ND	ND	2013	2013	A disinfection by-product
Molybdenum (ppb)	NA	NA	3.3	3.1-3.4	1.0	ND-1.9	3.4	3.2-3.5	2013	2013	A naturally-occurring element found in ores and present in plants, animals and bacteria
Strontium (ppb)	NA	NA	703	660-750	520	470-570	723	670-770	2013	2013	A naturally-occurring element
Vanadium (ppb) <sup>f</sup>	50	NA	See footnote f						2013	2013	A naturally-occurring elemental metal
ADDITIONAL CONSTITUENTS (UNREGULATED)											
Alkalinity (Total as CaCO3 ppm)	NA	NA	130	NA	150	NA			2018	2016	A measure of the capacity to neutralize acid
pH (units)	6.5-8.5 US EPA	NA	7.8	NA	6.7	NA			2018	2016	A measure of acidity or alkalinity
Bicarbonate Alkalinity HCO3 (ppm)	NA	NA	160	NA	180	NA			2018	2016	A measure of the capacity to neutralize acid
Boron (ppb)	NA	(1000)	200	NA	ND	NA			2018	2016	A naturally-occurring element
Calcium (ppm)	NA	NA	52	NA	47	NA			2018	2016	A naturally-occurring element
Magnesium (ppm)	NA	NA	25	NA	14	NA			2018	2016	A naturally-occurring element
Potassium (ppm)	NA	NA	3	NA	ND	NA			2018	2016	A naturally-occurring element
Total Hardness (ppm)	NA	NA	233 (13.6 grains/gal)	NA	175	NA			2018	2016	"Hardness" is the sum of polyvalent cations present in the water, generally magnesium and calcium. The cations are usually naturally occurring.
Sodium (ppm)	NA	NA	30	NA	50	NA			2018	2016	"Sodium" refers to the salt present in the water and is generally naturally occurring.

## TERMS USED IN THIS REPORT:

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Notification Level:** Health based advisory levels established by The State Board\* for chemicals in drinking water that lack MCLs.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Regulatory Action Level (RAL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique:** A required process intended to reduce the level of a contaminant in drinking water.

**UCMR 3:** Unregulated Monitoring Contaminant Rule (Third round). This monitoring helps the EPA and The State Board\* determine where certain contaminants occur and whether the contaminants need to be regulated.

## Key To Table (ACRONYMS)

NA = Not Applicable  
 ND = None Detected  
 NL = Notification Level  
 NS = No Sample  
 NTU = Nephelometric Turbidity Units (a measure of turbidity)  
 ppt = Parts per trillion, or nanograms per liter (ng/L)  
 pCi/L = Picocuries per liter (a measure of radiation)  
 ppm = Parts per million, or milligrams per liter (mg/L)  
 ppb = Parts per billion, or micrograms per liter (ug/L)  
 TT = Treatment Technique  
 uS/cm = Micro Siemens per Centimeter (a measure of specific conductance)

## Water Quality Table Footnotes:

- Turbidity is a measure of the cloudiness of water and is a good measure of water quality and filtration performance; 100% of the samples tested for turbidity were below the required TT level of 0.2 NTU and 100% is the lowest monthly percentage of samples meeting the turbidity limits.
- During 2018 Casitas collected 156 samples for total coliform bacteria testing according to the Total Coliform Rule. Total Coliform bacteria were not detected in any of these samples.
- Mira Monte Well is above the MCL for nitrate, however the well water is blended with Lake Casitas water with the resulting nitrate level averaging 0.8 ppm as nitrogen.
- The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.
- Casitas has implemented a corrosion control plan by adding a small amount of phosphate to the water to lower corrosivity and reduce copper levels.
- These results are below the detection limits for reporting and can only be used as an estimate. For vanadium sampling the highest level (in ppb) for the lake was 1.2 (ND for 2014), the well was 0.78 and 1.2 for the distribution system. Vanadium results of the treated water for 2018 were ND.
- Distribution system measurements taken with field kits (not certified laboratory results).

\* CA State Water Resources Control Board